

## Waukee School District Wind Turbine Site Assessment

H.) The rotor for this particular machine is only designed to turn 167 rpm at any given wind speed. This is because the Endurance S-343 machine is an induction based A/C generating unit. To be this it must match the cycles (wave length) of the grid feeding the property. The over speed controls are a redundant fail safe pneumatic disk brake design. There are 2 pneumatic brakes that apply separate from each other. One break is enough to stop the machine completely but again it is a fail safe design. The cut out speed for this machine is 54 mph. It will not start back up until it is in normal operation conditions.

I.) The S-343 machine is an upgrade from the S-350 machine. It has 2' longer blades and a larger gearbox. This allows more production. The S-250 had been in production for over 5 years and has been tested by NREL (National Renewable Energy Laboratory). The S-343 has been in production for 2 years now and has also been tested by NREL.

J.) Mid American Utilities has been notified of intentions for a 5KW Endurance wind turbine on their grid. Mid American Utilities has a net metering policy of 500 KW and under so we are well in the parameters of this policy.

K.) This is what is being decided in the P and Z meetings and the City Council meetings upcoming

L.) This site is conducive for a wind turbine. Please see the wind assessment attached to this page. The wind speeds are from AWS Truewind a site respected by the industry for accurate data. This also supplies a wind rose and wind speeds broken down by month.

M.) This site and turbine height will comply with all FAA regulations. There is no lighting required for the turbine as it is under the 200' height.

N.) The Waukee School District has more than adequate insurance that the turbine can be attached to with a rider. The insurance required by the utility company can also be attached to their existing insurance. This is what other customers of VanWall Energy have done in the past.

O.) The City of Waukee noise ordinance will suffice for this machine.

P.) Shadow flicker will not be an issue in this location.


Q.) Please let me know anything else necessary for this assessment.

Thanks,




Jesse Fenske

# VanVail ENERGY




Speed: 2.78 m/s @ 20m  
 Height: 30 m    Elevation: 0.0 m  
 Lat: 41.60420    Lon: -95.87652  
 Roughness: 0.3000  
 Mean Power Density: 211 W/m<sup>2</sup>  
 Weibull A: 6.53 Weibull c: 2.175

### Wind Rose



### Monthly Speed Distribution





S-Series Interconnection Supplement | S-Series



[endurancewindpower.com](http://endurancewindpower.com)

Green energy that works™

# S-Series Interconnection Supplement

---

Version 1.9

June 14, 2010

© Endurance Wind Power Inc.

[www.endurancewindpower.com](http://www.endurancewindpower.com)

## Contents

<b>Introduction</b> .....	<b>1-1</b>
<b>Interconnection Characteristics</b> .....	<b>1-1</b>
<b>Generator Characteristics</b> .....	<b>1-1</b>
Generator Technical Data .....	1-1
Additional Induction Generator Data .....	1-1
Motoring characteristics .....	1-1
<b>Protection Equipment</b> .....	<b>1-1</b>
Disconnect Switch: .....	1-1
Interconnection Protective Relay: .....	1-1
SEL-547 Interconnection Relay .....	1-2
Over Current: .....	1-2
<b>Control Panel</b> .....	<b>1-2</b>
<b>Metering</b> .....	<b>1-2</b>
<b>Power Quality</b> .....	<b>1-2</b>
Power Factor .....	1-2
Total Harmonic Distortion .....	1-2
Voltage Fluctuations .....	1-2

## Introduction

This document is intended to assist dealers in establishing an interconnection agreement with the local utility for the Endurance 5kW wind turbine system.

## Interconnection Characteristics

Grid connection: Direct  
 Inverter: None

## Generator Characteristics

### Generator Technical Data

Generator type: Induction  
 Generator speed: 1800-1850 rpm  
 Voltage: 240 VAC single phase above 1.5 kW, 120VAC single phase below 1.5 kW  
 Manufacturer: Marathon Electric  
 Model: ME040292  
 Frame Size: 184-TC  
 Certification: UL 1004  
 CSA C22.2 No. 100

### Additional Induction Generator Data

Rotor Resistance, Rr: 0.550  $\Omega$   
 Rotor Reactance, Xr: 1.106  $\Omega$   
 Magnetizing Reactance, Xm: 35.69  $\Omega$   
 Exciting Current: 2.8Amps @ 240V, 60 Hz  
 Stator Resistance, Rs: Main = .417  $\Omega$   
 Aux = .836  $\Omega$   
 Stator Reactance, Xs: X1M = 1.309, X1A = 1.560  $\Omega$   
 Short Circuit Reactance, Xd: 3.236 (100MVA base the pu would be 12944000)  
 Rotor inertia: 0.018 kg-m<sup>2</sup>

Table 1. Generating Characteristics

Characteristic	S-250	S-343
Rated Power (kW)	4.3	5.2
Rated VA (kVA)	4.6	5.9
Rated Current (A)	19.2	24.4
Peak Power (kW)	5.8	5.9
Peak VA (kVA)	6.3	6.7
Peak Current (A)	26.4	27.9

### Motoring characteristics

The generator is used as a motor to start the rotor from the stopped rotor position. This will occur no more than once every 10 minutes and typically no more than a few times per day.

Motoring Voltage: 120 VAC single phase

Motoring Current: ~41 A  
 Motoring VA: ~5,000 VA  
 Motoring Time: <8 seconds typical (dependent on wind speed at the time)

## Protection Equipment

### Disconnect Switch:

The wind turbine installation requires a lockable disconnect switch which is clearly labeled "WIND GENERATOR DISCONNECT SWITCH". This disconnect switch can be located at either the base of the tower or at the utility connection.

### Interconnection Protective Relay:

The Endurance S-Series turbines come equipped with distributed generation interconnection relay protection. The relay will monitor and disconnect the wind turbine generator during conditions of over/under voltage and/or over/under frequency resulting from either a system wide voltage/frequency disturbance or due to local system islanding. Phase loss will also be detected since both legs of the single-phase 240 VAC connection will be monitored separately at all times. These monitoring parameters have been determined by IEEE1547.

Any out-of-bound condition will result in the turbine disconnecting from the local utility grid. After the grid has been restored, a minimum "off-line" wait

## S-Series Interconnection Supplement

**Table 2. SEL interconnection relay settings**

Monitored Parameter	ANSI Device #	Setting	Voltage or Frequency (based on 120VAC/60Hz Nom.)	Cycles to Disconnect	Time to Disconnect (sec.)
under-voltage (level 1)	27	50% Nom.	60 VAC	6	0.1
under-voltage (level 2)	27	88% Nom.	106 VAC	108	1.8
over-voltage (level 1)	59	110% Nom.	132 VAC	48	0.8
over-voltage (level 2)	59	120% Nom.	144 VAC	6	0.1
under-frequency (level 1)	81	95% Nom.	57 Hz	6	0.1
under-frequency (level 2)	81	98.8% Nom.	59.3 Hz	6	0.1
over-frequency (level 1)	81	100.8% Nom.	60.5 Hz	6	0.1

period of 5 minutes will be imposed before the turbine resumes normal operation.

### *SEL-547 Interconnection Relay*

Table 2 documents parameter settings for the Schweitzer Engineering Laboratories SEL-547 utility interconnection relay; other custom settings can be accommodated.

### *Over Current:*

The wind turbine will be protected by a main circuit breaker. This breaker will be a 40 A - 240 VAC 2 pole.

### **Control Panel**

The control panel is housed in a NEMA Type 4 & Type 12 enclosure and is typically mounted at the base of the tower [CSA C22.2 No. 14-05, UL 508A].

### **Metering**

We recommend the wind turbine system be metered allowing for an evaluation of energy production. A standard 240 V utility meter is adequate.

### **Power Quality**

#### *Power Factor*

The power factor (PF) has been measured using a Phaser watt transducer (accuracy 0.3%). Data was collected at 5 Hz and averaged for 1 minute then binned into 500 watt bins, shown in Figure 3 on page 1-4.

#### *Total Harmonic Distortion*

Total harmonic distortion (THD) has been measured using a Phaser watt transducer (accuracy

0.5%). The Phaser can be configured to calculate either THD-F, a ratio of the harmonics to the fundamental or THD-R, a ratio of the harmonics to the RMS of the input. Both THD-F and THD-R were collected. Data was collected at 5 Hz and averaged for 1 minute then binned into 500 watt bins, as shown in Figure 2 on page 1-4.

Both values are shown to be as high as 1.5% dropping to less than 1.0% at the higher power levels.

#### *Voltage Fluctuations*

The Endurance has been designed to minimize voltage fluctuations (voltage sag or flicker) that can occur when an induction generator is connected with the utility grid. There are three key elements used to reduce these voltage sags.

1. The generator is connected at 120 VAC. By using a lower voltage the power draw is cut by 75%.
2. A power resistor is switched in at the moment of contact resulting in a voltage drop across the resistor and therefore a further reduction in current draw, which reduces flicker during start-up.
3. The control program has been designed to use hysteresis which limits the number of on- and off-line cycles in a given time.

Measurements were taken at our test facility to evaluate the percent drop in voltage during an on-line connection. Although it is understood that the voltage sag will be somewhat site-dependent on the local system impedance we suspect that our test facility, which is located on the end of the utility line, will represent a higher system impedance.

Our analysis of 10 on-line events showed an average voltage sag of 1.9% with a standard deviation of 0.55%. This process evaluated the RMS value of the single voltage cycle with the highest voltage drop after contact. Nominal voltage is typically recovered within a single voltage cycle; hence this approach determined the largest percent voltage sag due to the event.

Using the plot shown in Figure 1 from IEEE we see that a voltage sag of this magnitude is allowed if its frequency is less than ~1 event/minute. The current control limits on- and off-line cycling via a hysteresis algorithm. Data collected on a turbine operating in the field indicates the effectiveness of this approach. During winds that are fluctuating around cut-in, the highest frequency experienced by the machine for 7 on/off-line connections was 0.85 events/minute with the highest frequency between any two consecutive events at 1.17 events/minute.




Figure 1. IEEE Stds 141 & 519 flicker curves

## S-Series Interconnection Supplement




Figure 2. Total harmonic distortion




Figure 3. Measured power factor





Figure 4. System synopsis



PLANS PREPARED FOR:  
**Endurance**  
 wind power  
 #107-109052, 26th Ave.  
 Surrey, BC Canada V3S 3V7  
 Office: (604)-628-5432

PROJECT INFORMATION:  
**104-FT ± [31.7M ±]  
 MONOPOLE  
 MODIFICATION  
 (90-FT ± MODIFIED  
 HUB HEIGHT)**




PLANS PREPARED BY:  
  
**TOWER ENGINEERING PROFESSIONALS**  
 3703 JUNCTION BOULEVARD  
 RALEIGH, NC 27603-5263  
 OFFICE: (919) 661-6351  
 FAX: (919) 661-6350

SEAL:  
  
**G. M. ANDRES**  
 # 30869  
 BRITISH COLUMBIA  
 PROFESSIONAL ENGINEER  
 October 16, 2009

3	10-26-09	REVISED PER CLIENT
2	10-15-09	REVISED PER CLIENT
1	09-14-09	REVISED PER CLIENT
0	09-09-09	MODIFICATION DRAWINGS
REV	DATE	ISSUED FOR:
DRAWN BY: JAS CHECKED BY: KAM		

SHEET TITLE:  
**TOWER ELEVATION &  
 MODIFICATION  
 DETAILS**

SHEET NUMBER:  
**S-1**  
 REVISION: **3**  
 TEP # 090421



**INDEX OF SHEETS**

NO.	SHEET TITLE	REV	DATE
5-1	TOWER ELEVATION MODIFICATION SCHEDULE	3	10-26-09
5-2	PROJECT NOTES	3	10-26-09

